


901 door entry system

Wiring Diagram



ns

as an onto
rician ces. A led to ner is

ts:

ation. flush-it door,

pening imount

d using e R & O

port.

a single

ly adjust

Unit by length of rs. Note:

bell system

door entry and access control systems

Installation of Door Entry Systems

Important Safety Information:

The Power Supply Unit must be placed in a protected indoor environment such as an electrical cupboard, close to a 230V AC electrical supply. It must be wall-mounted onto plasterboard, wood or a similar non-conductive material.

Connections to the 230V AC mains supply must be carried out by a qualified electrician or similar competent person, and made in accordance with accepted safety practices. A two-pole switch (as provided by a Consumer Unit or Switch-Fuse) must be included to isolate both Live and Neutral during Installation or Maintenance. The transformer is protected by fuses; always replace these with the correct type and rating.

Use only mains cable to BS6004 or equivalent, within the following specified limits:

Conductor Diameter:	Min. 1.0mm (0.8mm ²)	Max. 2.25mm (4mm ²)
Cable diameter:	Min. 4.0mm	Max. 8.0mm

The Door Entry Telephone is designed to be wall-mounted in a convenient indoor location.

The Entrance panel, containing the speech unit, is available with either a surface or flush-mounting back box. Normally this would be mounted on an outside wall near the front door, and if possible in a sheltered location.

The Model 203 Electric Lock Release (optional) is designed for use on an inward opening door fitted with a surface night-latch type lock. This should be installed with a small amount of play on the door as operation will be impaired if too tight.

Cable requirements:

For optimum speech clarity, it is strongly recommended that this system is installed using twisted-pair telephone cable (eg type CW1308 or CAT5e). Use one of the pairs for the R & O connections between the speech unit and the telephone.

For cable distances greater than 50m or for other lock releases contact Technical Support.

Installation:

Connect all items by following the wiring diagram. It is strongly recommended that a single telephone be connected at a time and fully tested before proceeding to the next.

Speech adjustment:

The speech unit has two controls at the rear for adjustment of speech levels:

Volume A: Speech level at the Entrance Panel

Volume B: Speech level at the Telephone

If feedback is experienced (a howl or whistle) turn both controls to 'off' and then slowly adjust each up in turn until a satisfactory level of speech is attained.

Troubleshooting:

No speech / insufficient speech: Initially establish correct operation of the Speech Unit by disconnecting all telephones and re-connecting a single telephone with a short length of cable (ROT only); Reconnect the telephones one at a time until the fault re-appears. Note: speech will be impaired if one or more telephones are left off the hook.

This product complies with European directive 2004/108/EC on
Electromagnetic Compatibility and Low Voltage Directive 2006/95/EC
Emissions: Generic BSEN 61000-6-3
Immunity: Generic BSEN 61000-6-1
Low Voltage: BSEN 60950

Do

Call

61